

# PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Center Stage Discos
Address:	<div style="background-color: black; width: 100px; height: 15px; margin-bottom: 5px;"></div> <div style="background-color: black; width: 100px; height: 15px; margin-bottom: 5px;"></div> Holbeach <span style="background-color: black; width: 20px; height: 15px; display: inline-block;"></span> Spalding Lincolnshire PE12 8 <span style="background-color: black; width: 20px; height: 15px; display: inline-block;"></span>



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	MJ PAT Testing
Address:	6 Union Place Wisbech Cambridgeshire PE13 1HB
Telephone:	07342 203158
Mobile:	
Email:	info@mjpattesting.co.uk
Web:	www.mjpattesting.co.uk
Cert Number:	MJPT-210507
Order Number:	
Signature:	

## ACCREDITATION DETAILS



## APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (KVA)	Leakage (mA)	Overall Status	
<b>TRAFALGAR SQUARE - STORE ROOM</b>										
1544	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.10	P 19.99	S	S	PASS	
1545	IEC LEAD IEC LEAD 2METRE	20/08/21	P	P	P 0.01	P 19.99	S	S	PASS	
1546	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS	
1547	IEC LEAD IEC LEAD 2 METRE	20/08/21	P	P	P 0.01	P 19.99	S	S	PASS	
1548	IEC LEAD IEC 1 METRE LEAD	20/08/21	P	P	P 0.04	P 19.99	S	S	PASS	
1550	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.07	P 19.99	S	S	PASS	
1551	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.05	P 19.99	S	S	PASS	
1552	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS	
1553	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.05	P 19.99	S	S	PASS	
1554	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.05	P 19.99	S	S	PASS	
1555	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.05	P 19.99	S	S	PASS	
1556	IEC LEAD IEC 2 METRE LEAD	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS	
1557	EXTENSION LEAD EXTENSION LEAD 4 METRE	20/08/21	P	P	P 0.11	P 19.99	S	S	PASS	
1558	EXTENSION LEAD EXTENSION LEAD 6 METRE	20/08/21	P	P	P 0.11	P 19.99	S	S	PASS	
1559	EXTENSION LEAD EXTENSION LEAD 1.8 METRE	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS	
1560	EXTENSION LEAD EXTENSION LEAD 1.5 METRE	20/08/21	P	P	P 0.05	P 19.99	S	S	PASS	

**APPLIANCE DETAILS AND TEST RESULTS**
**Key**  
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
1561	EXTENSION LEAD EXTENSION LEAD 4 METRE	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS
1562	EXTENSION LEAD EXTENSION LEAD 2 METRE	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS
1563	EXTENSION LEAD EXTENSION LEAD 2 METRE	20/08/21	P	P	P 0.06	P 19.99	S	S	PASS
1564	EXTENSION LEAD EXTENSION LEAD 2 METRE	20/08/21	P	P	P 0.09	P 19.99	S	S	PASS
1565	EXTENSION LEAD EXTENSION LEAD 37 METRE	20/08/21	P	P	P 0.53	P 19.99	S	S	PASS
1566	EXTENSION LEAD EXTENSION LEAD 37 METRE	20/08/21	P	P	P 0.52	P 19.99	S	S	PASS
1567	SPEAKER EVOLUTION EL-SUB-15A	20/08/21	P	S	P 0.10	P 19.99	S	S	PASS
1568	SPEAKER EVOLUTION EL-SUB-15A	20/08/21	P	S	P 0.09	P 18.32	S	S	PASS
1569	LIGHT / LAMP INCREDIBLED LED-410	20/08/21	P	S	P 0.09	P 19.99	P <0.05	P <0.10	PASS
1570	SPEAKER EVOLUTION RZ12A V3	20/08/21	P	S	P 0.09	P 19.99	S	S	PASS
1571	SPEAKER EVOLUTION RZ12A V3	20/08/21	P	S	P 0.10	P 19.99	S	S	PASS
1572	CONTROLLER MARTIN 2510	20/08/21	P	S	P 0.09	P 19.99	S	S	PASS
1573	LIGHT / LAMP QTX LIGHT LED TWISTER II	20/08/21	P	S	P 0.09	P 19.99	P <0.05	P <0.10	PASS
1574	LIGHT / LAMP CHAUVET SWARM 5FX	20/08/21	P	S	P 0.09	P 19.99	P <0.05	P 0.24	PASS
1575	LIGHT / LAMP CHAUVET SWARM 5FX	20/08/21	P	S	P 0.10	P 19.99	P <0.05	P 0.23	PASS
1576	FOGGER ACME HP-3	20/08/21	P	S	P 0.10	P 19.99	P 1.02	P <0.10	PASS
1577	LIGHT / LAMP MARTIN ROBOSCAN 812	20/08/21	P	S	P 0.10	P 19.99	P <0.05	P <0.10	PASS
1578	LIGHT / LAMP MARTIN ROBOSCAN 812	20/08/21	P	S	P 0.10	P 19.99	P <0.05	P <0.10	PASS
1579	LIGHT / LAMP MARTIN ROBOSCAN 812	20/08/21	P	S	P 0.09	P 19.99	P <0.05	P <0.10	PASS
1580	IEC LEAD IEC FIG 8	20/08/21	P	S	S	P 19.99	S	S	PASS
1581	POWER ADAPTER TOSHIBA	20/08/21	P	S	S	P 19.99	S	S	PASS
1582	LIGHT / LAMP ACME DYNAMO 250	20/08/21	P	S	P 0.10	P 19.99	P <0.05	P <0.10	PASS
1583	LIGHT / LAMP ACME DYNAMO 250	20/08/21	P	S	P 0.09	P 19.99	P <0.05	P <0.10	PASS
1584	LIGHT / LAMP MARTIN MANIA EF2 EU	20/08/21	P	S	P 0.10	P 19.99	P 0.13	P <0.10	PASS
1585	LIGHT / LAMP ACME DYNAMO 250	20/08/21	P	S	P 0.10	P 19.99	P <0.05	P <0.10	PASS
1586	LIGHT / LAMP MARTIN MANIA EF2 EU	20/08/21	P	S	P 0.10	P 19.99	P 0.13	P <0.10	PASS

 Total Appliances > **42**
**Total Appliances For Report: 42**