

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

ORIGINAL CERTIFICATE

CERTIFICATE REFERENCE: 03022025/CSD

DETAILS OF CLIENT

Centre Stage Discos
Auckland Farm, Ravens Drove, Holbeach, Spalding Lincs, PE12 8SN

TEST EQUIPMENT DETAILS

TEST EQUIPMENT USED: Eurotest EASI M13100S SERIAL NUMBER: 20150320

TESTED BY: B. Walker 07738 614 151 DATE: 03/02/2025 RETEST DATE: 02/02/2026

Signed:

Serial Number	Make and model	Fuse rating (Amps)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use?
0001	RCF Sub 705-AS 2 Speaker S/N VDXY07302	13a	>200MΩ	✓	✓	YES
0002	RCF Sub 705-AS 2 Speaker S/N VDXQ07310	13a	>200MΩ	✓	✓	YES
0003	RCF ART 912-A Speaker S/N VFQZ00029	13a	>200MΩ	✓	✓	YES
0004	RCF ART 912-A Speaker S/N VFQG00028	13a	>200MΩ	✓	✓	YES
0005	Evolution EL-SUB-15A Speaker	13a	>200MΩ	✓	✓	YES
0006	Evolution EL-SUB-15A Speaker	13a	145MΩ	✓	✓	YES
0007	Evolution RZ12A V3 Speaker	13a	>20MΩ	✓	✓	YES
0008	Evolution RZ12A V3 Speaker	13a	>20MΩ	✓	✓	YES
0009	Chauvet DJ Swarm 5FX Light S/N 10050765-1113002401	13a	>20MΩ	✓	✓	YES
0010	Chauvet DJ Swarm 5FX Light (S/N Missing)	13a	>20MΩ	✓	✓	YES
0011	Acme IncredibLed Light S/N PL-12082850 -A00	13a	>20MΩ	✓	✓	YES
0012	Martin Mania EF 2 Light S/N (21)0003297089	13a	>20MΩ	✓	✓	YES
0013	Martin Mania EF 2 Light S/N (21)0003297106	13a	>20MΩ	✓	✓	YES
0014	Acme Dynamo DMX 250 Light S/N PL-10070667	13a	>20MΩ	✓	✓	YES
0015	Acme Dynamo DMX 250 Light S/N PL-10070627	13a	>20MΩ	✓	✓	YES
0016	Acme Dynamo DMX 250 Light S/N PL-10070592	13a	>20MΩ	✓	✓	YES
0017	Acme Dynamo DMX 250 Light S/N PL-10070664	13a	>20MΩ	✓	✓	YES
0020	LEDJ Event Spot RGBW Light	13a	>20MΩ	✓	✓	YES
0021	LEDJ Event Spot RGBW Light	13a	>20MΩ	✓	✓	YES
0022	BeamZ SparkeWall LED Starcloth Controller S/N 14530	13a	>20MΩ	✓	✓	YES
0024	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0025	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0026	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0027	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0028	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0029	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0030	Lenovo Power Supply Cable for 0031	13a	>20MΩ	✓	✓	YES
0031	Lenovo Power Supply S/N 8SSA10A33633L1CZ45D017D	13a	>20MΩ	✓	✓	YES
0032	Lenovo Laptop Power Supply S/N 8SSA10J201148D18G81X09YN	13a	>20MΩ	✓	✓	YES
0036	Tyco Lit Uplight	13a	>20MΩ	✓	✓	YES
0045	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

ORIGINAL CERTIFICATE

CERTIFICATE REFERENCE: 03022025/CSD

DETAILS OF CLIENT

Centre Stage Discos
Auckland Farm, Ravens Drove, Holbeach, Spalding Lincs, PE12 8SN

TEST EQUIPMENT DETAILS

TEST EQUIPMENT USED: Eurotest EASI M13100S SERIAL NUMBER: 20150320

TESTED BY: B. Walker 07738 614 151 DATE: 03/02/2025 RETEST DATE: 02/02/2026

Signed:

Serial Number	Make and model	Fuse rating (Amps)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use?
0046	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0047	IEC Lead 3 Metre Approx.	13a	>20MΩ	✓	✓	YES
0051	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0054	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0055	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0056	IEC Ext. Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0057	IEC Extension Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0058	4 Gang Extension Lead 3 Metre Approx.	13a	>20MΩ	✓	✓	YES
0059	1 Gang Extension Lead 3 Metre Approx.	13a	>20MΩ	✓	✓	YES
0060	1 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0061	1 Gang Extension Lead 6 Metre Approx.	13a	>20MΩ	✓	✓	YES
0063	6 Gang Extension Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0064	2 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0065	USB Power Adapter	13a	>20MΩ	✓	✓	YES
0066	6 Gang Switched Extension Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0067	1 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0068	Acme HP-3 Fogger S/N AE-HP3E0407000778	13a	>20MΩ	✓	✓	YES
0069	Chauvet DJ Hurricane 700 S/N 09070323-0118000536	13a	>20MΩ	✓	✓	YES
0070	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0071	6 Gang Extension Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0074	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0075	IEC Lead 3 Metre Approx.	13a	>20MΩ	✓	✓	YES
0076	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0077	2 Gang Extension Lead 8 Metre Approx.	13a	>20MΩ	✓	✓	YES
0079	4 Gang Extension Lead 3 Metre Approx.	13a	>20MΩ	✓	✓	YES
0080	2 Gang Extension Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0084	IEC Ext. Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0085	IEC Ext. Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0086	1 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0090	IEC Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0091	IEC Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

ORIGINAL CERTIFICATE

CERTIFICATE REFERENCE: 03022025/CSD

DETAILS OF CLIENT

Centre Stage Discos
Auckland Farm, Ravens Drove, Holbeach, Spalding Lincs, PE12 8SN

TEST EQUIPMENT DETAILS

TEST EQUIPMENT USED: Eurotest EASI M13100S SERIAL NUMBER: 20150320

TESTED BY: B. Walker 07738 614 151 DATE: 03/02/2025 RETEST DATE: 02/02/2026

Signed:

Serial Number	Make and model	Fuse rating (Amps)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use?
0093	IEC Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0094	IEC Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0095	IEC Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0096	IEC Ext. Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0097	IEC Ext. Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0098	1 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0099	1 Gang Extension Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0100	4 Gang Switched Extension Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0101	IEC Ext. Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0109	IEC Lead 1 Metre Approx.	13a	>20MΩ	✓	✓	YES
0111	IEC Ext. Lead 4 Metre Approx.	13a	>20MΩ	✓	✓	YES
0112	2 Gang Extension Lead 2 Metre Approx.	13a	>20MΩ	✓	✓	YES
0113	2 Gang Extension Lead 8 Metre Approx.	13a	>20MΩ	✓	✓	YES
0114	1 Gang Extension Lead 20 Metre Approx.	6a	>20MΩ	✓	✓	YES
0115	1 Gang Extension Lead 20 Metre Approx.	6a	>20MΩ	✓	✓	YES
0116	1 Gang Extension Lead 10 Metre Approx.	6a	>20MΩ	✓	✓	YES
0117	1 Gang Extension Lead 10 Metre Approx.	6a	>20MΩ	✓	✓	YES
0119	1 Gang Extension Lead 10 Metre Approx.	6a	>20MΩ	✓	✓	YES
0121	1 Gang Extension Lead 5 Metre Approx.	6a	>20MΩ	✓	✓	YES
0128	Fusion Scan EQLED032B	2.5a	>20MΩ	✓	✓	YES
0129	Fusion Scan EQLED032B	2.5a	>20MΩ	✓	✓	YES
0130	Kinta HP LED Derby	1a	>20MΩ	✓	✓	YES
0131	Kinta HP LED Derby	1a	>20MΩ	✓	✓	YES
0133	Studiomaster Club XS10+ Mixing Desk	T1AL	>20MΩ	✓	✓	YES
0134	IEC Lead 1 Meter Approx.	13a	>20MΩ	✓	✓	YES
0135	IEC Lead 1 Meter Approx.	13a	>20MΩ	✓	✓	YES
0136	IEC Lead 1 Meter Approx.	13a	>20MΩ	✓	✓	YES
0137	4 Gang Extension Lead 1 Meter Approx.	13a	>20MΩ	✓	✓	YES
0138	USB Power Adapter	13a	>1.5MΩ	✓	✓	YES
0140	2 Pin Adapter	1a	>20MΩ	✓	✓	YES
0141	USB Plug	3a	>3MΩ	✓	✓	YES

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

ORIGINAL CERTIFICATE

CERTIFICATE REFERENCE: 03022025/CSD

DETAILS OF CLIENT

Centre Stage Discos
Auckland Farm, Ravens Drove, Holbeach, Spalding Lincs, PE12 8SN

TEST EQUIPMENT DETAILS

TEST EQUIPMENT USED: Eurotest EASI M13100S SERIAL NUMBER: 20150320

TESTED BY: B. Walker 07738 614 151 DATE: 03/02/2025 RETEST DATE: 02/02/2026

Signed:

Serial Number	Make and model	Fuse rating (Amps)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use?
0143	Studiomaster Club XS8 Mixing Desk	T1AL	>20MΩ	✓	✓	YES
0144	Lava Lamp	3a	>20MΩ	✓	✓	YES
0145	Lava Lamp	3a	>20MΩ	✓	✓	YES
0146	Acme Smoke Machine HP3 Fogger	13a	>20MΩ	✓	✓	YES
0153	Belaco Fan	13a	>20MΩ	✓	✓	YES
0154	Belaco Fan	13a	>20MΩ	✓	✓	YES
0155	USB Adapter Black	13a	>20MΩ	✓	✓	YES
0156	LED Boogie	13a	>20MΩ	✓	✓	YES
0157	LED Boogie	13a	>20MΩ	✓	✓	YES
0158	Challenge Fan Heater	13a	>20MΩ	✓	✓	YES
0159	4 Gang Extension Lead 3m Approx	13a	>20MΩ	✓	✓	YES
0160	4 Gang Extension Lead 2m Switched	13a	>20MΩ	✓	✓	YES
0161	4 Gang Extension Lead 3m	13a	>20MΩ	✓	✓	YES
0162	4 Gang Extension Lead 3m	13a	>20MΩ	✓	✓	YES
0163	IEC Cable 3m	13a	>20MΩ	✓	✓	YES